



EMISSION TESTING CONSULTANTS

4 July 2008

Report No: 070345r

Page: 1 of 9

Report prepared for:
Neal Scholer Incineration
Welshpool, WA

Emission Testing – June 2008
Turbo-Burn

Dear Mr Neal Scholer,

Tests were performed 17 June 2008 to determine emissions to air from the Turbo-Burn portable incineration unit.

DEFINITIONS2
 PLANT OPERATING CONDITIONS3
 SAMPLING PLANE REQUIREMENTS5
 SAMPLING PLANE OBSERVATIONS5
 TEST METHODS6
 DEVIATIONS FROM TEST METHODS7
 RESULTS8
Turbo-Burn.....8

Yours faithfully
Emission Testing Consultants

Stephen Pereira
Manager – Western Australia

sp@emission.com.au



NATA Accredited
Laboratory Number: 14601

This document is issued in accordance with NATA's accreditation requirements.



DEFINITIONS

The following symbols and abbreviations are used in this test report:

NTP	Normal temperature and pressure. Gas volumes and concentrations are expressed on a dry basis at 0°C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa, unless otherwise specified.
Nm ³ /min	Flow rate (m ³ /min) at NTP conditions
Disturbance	A flow obstruction or instability in the direction of the flow that may impede accurate flow determination. This includes centrifugal fans, axial fans, partially closed or closed dampers, louvres, bends, connections, junctions, direction changes or changes in pipe diameter.
BSP	British standard pipe.
VOC	wAny chemical compound based on carbon in the boiling range 36 to 126°C, with a vapour pressure of at least 0.010kPa at 25°C (or having a corresponding volatility under the particular conditions of use) that adsorb onto activated charcoal and desorb into CS ₂ , or that can be collected in a tedlar bag and be quantitatively recovered, and that are detected by GCMS. These compounds may contain oxygen, nitrogen and other elements, but specifically excluded are CO, CO ₂ , carbonic acid, metallic carbides and carbonate salts.
D	Duct diameter or equivalent duct diameter for rectangular ducts.
>	Greater than
<	Less than the minimum limit of detection using the specified method.
~	Approximately
NA	Not applicable

PLANT OPERATING CONDITIONS

The Turbo-Burn was operated in accordance with the 'Information and Service Manual' supplied with the unit.

WASTE COMPOSITION

The waste composition was carefully measured and recorded.

Waste	Mass (kg)
Oil filters	11.1
Oily rags (and absorbants)	13.5
Plastics	2.35
Oil	5
Paper, cardboard & wood	9.45
TOTAL WASTE	41.4



Oil filters – 11.1kg



Oily rags – 13.5kg



Plastics – 2.35kg



Waste oil – 5kg



Paper, cardboard & wood – 9.45



Total – 41.4kg

BURN-DOWN

The unit was extinguished when the burn cycle was deemed complete by the operator. The ash and non-combustibles were carefully weighed once cool.

Final weights	Mass (kg)
Ash	2.1
Filter canisters	7.15
TOTAL	9.25



SAMPLING PLANE REQUIREMENTS

Criteria for Sampling Planes for compliance to Australian Standard (AS 4323.1-1995)

Table 1

Type of flow disturbance	Minimum distance upstream from disturbance, diameters (D)	Minimum distance downstream from disturbance, diameters (D)
Bend, connection, junction, direction change, exit	> 2D	>6D
Louvre, butterfly damper (partially closed or closed)	>3D	>6D
Axial fan	>3D	>8D (see note)
Centrifugal fan	>3D	>6D

Note: The plane should be selected as far as practicable from a fan. Flow straighteners may be required to ensure the position chosen meets the check criteria listed in items (a) to (f) below.

- (a) The gas flow is basically in the same direction at all points along each sampling traverse.
- (b) The gas velocity at all sampling points is greater than 3 m/sec.
- (c) The gas flow profile at the sampling plane shall be steady, evenly distributed and not have a cyclonic component which exceeds an angle of 15° to the duct axis, when measured near the periphery of a circular sampling plane.
- (d) The temperature difference between adjacent points of the survey along each sampling traverse is less than 10% of the absolute temperature, and the temperature at any point differs by less than 10% from the mean.
- (e) The ratio of the highest to lowest pitot pressure difference shall not exceed 9:1 and the ratio of the highest to lowest gas velocities shall not exceed 3:1. For isokinetic testing with the use of impingers, the gas velocity ratio across the sampling plane shall not exceed 1.6:1.
- (f) The gas temperature at the sampling plane should preferably be above the dewpoint.

SAMPLING PLANE OBSERVATIONS

As the sample was taken at the stack exit, the sampling plane was not in accordance with **Table 1** of **AS4323.1** but the conditions of checklist **(a)** to **(f)** of **AS 4323.1** were met.

The accuracy of results should not be affected.

TEST METHODS

The following methods are accredited with National Association of Testing Authorities (NATA).

All parameters will be reported adjusted to dry NTP conditions unless otherwise stated.

On site sampling guidelines: according to ETC method 1.

Sampling plane criteria: according to AS 4323.1-1995. Selection of sampling positions.

Flow rate and velocity: according to USEPA Method 2, using a pitot tube and differential manometer. Temperature determined using a calibrated thermocouple and digital pyrometer.

Moisture content: according to USEPA method Alt008, by gravimetry.

Particulate matter: according to USEPA method 17. Determination of total particulate matter - Isokinetic manual sampling - Gravimetric method, using the quartz thimble holder, in the in-stack configuration.

Oxygen: according to US EPA method 3A, using an electrochemical cell O₂ analyser in conjunction with an electronic cooler unit. Calibration against NATA certified gas standard of O₂ in nitrogen.

Carbon dioxide: according to US EPA method 3A, using a NDIR CO₂ analyser in conjunction with an electronic cooler unit. Calibration against NATA certified gas standard of CO₂ in N₂.

Carbon monoxide: according to US EPA method 10, using an NDIR CO analyser in conjunction with an electronic cooler unit. Calibration against NATA certified gas standard of CO in N₂.

Sulphur dioxide: according to USEPA method 6C, using an NDIR SO₂ analyser in conjunction with an electronic cooler unit. Calibration against NATA certified gas standard of SO₂ in N₂.

Nitrogen oxides (NO and NO₂) as NO₂: according to US EPA method 7E, using a chemiluminescence NO_x analyser in conjunction with an electronic cooler unit. Calibration against NATA certified gas standard NO/NO₂ in N₂.

Total (gaseous and particulate) metals and metallic compounds: according to USEPA method 29, by on site isokinetic sampling into a sampling train consisting of a heated filter followed by impingers. Subsequent analysis by atomic absorption spectrometry (AAS) or inductive coupled plasma (ICP) spectrometry. *Analysis under subcontract by National Measurement Institute in report number RN686898, dated 3 July 2008.*

Hydrogen chloride: according to USEPA Method 26, by on site sampling into an impinger train with subsequent analysis by ion chromatography. *Analysis performed under subcontract by SGS Environmental in report number 61926, dated 1 July 2008 (NATA accreditation number 2562).*

Volatile organic compounds: according to USEPA method 18, by on site sampling into sorbent tube, with subsequent laboratory analysis by solvent desorption and GC-FID. *Analysis performed under subcontract by MGT Environmental Consulting in report number 229271, dated 2 July 2008 (NATA accreditation number 1261).*

DEVIATIONS FROM TEST METHODS

USEPA Methods 2 & 17

Flow measurements and isokinetic sampling was conducted at a single representative point throughout the burn cycle.

A flow measurement and temperature was taken at the same position as the isokinetic nozzle every 10 minutes. Isokinetic rate was adjusted accordingly.

Particulate matter and heavy metals were tested for the duration of the burn.

OBSERVATIONS – VISIBLE EMISSION

There was no significant visible emission. There were short periods of visible emission during startup and burnout. The thickest / densest visible emission could be rated against the Ringelmann Chart as between 0 and 1 (zero and one).

RESULTS

Turbo-Burn 17 June 2008

Sampling Plane Details	
Distance upstream from disturbance:	Sampled at exit
Distance downstream from disturbance:	> 6 D from Connection
Discharge to air:	Vertical
Size and number of ports:	nil
Access to ports:	Portable step ladder
Conformance with AS 4323.1 Table 1:	No*
Non conformance with these items of AS 4323.1:	Conforms with all items



Flow Results		
Time of flow tests	12:40 to 14:40	hrs
Stack dimensions at sampling plane	250	mm
Velocity at sampling plane	8.7	m/s
Average temperature	260	°C
Average moisture content	3.1	%v/v
Flow rate at discharge conditions	26	m ³ /min
Flow rate at wet NTP conditions	12	m ³ /min
Flow rate at dry NTP conditions	11	m ³ /min

Manual Sampling Results	Sampling Times	Concentration at NTP	Mass rate
Chloride as HCl	1235-1450	2.9 mg/m ³	0.033 g/min

Volatile Organic Compound (VOC) Results	Sampling Times	Concentration at NTP	Mass rate
Total VOC as n-hexane	1235-1450	10 mg/m ³	0.11 g/min

Refer to "**SAMPLING PLANE OBSERVATIONS**" on page 3.

Refer to "**DEVIATIONS FROM TEST METHODS**" on page 7.

Turbo-Burn

17 June 2008

Continuous Analyser Results	Sampling Times	Concentration	Mass rate
Oxygen (dry basis)	1245-1447	18.5 % v/v	-
Carbon dioxide (dry basis)	1245-1447	2.3 % v/v	30 kg/hour
Dry gas density	1245-1447	1.3 kg/Nm ³	-
Molecular weight of stack gas, dry basis	1245-1447	29 g/g-mole	-
Nitrogen oxides as NO ₂	1245-1447	39 mg/Nm ³	0.43 g/min
Nitrogen oxides as NO ₂ (Minimum)	1245-1447	9.1 mg/Nm ³	0.10 g/min
Nitrogen oxides as NO ₂ (Maximum)	1245-1447	87 mg/Nm ³	0.98 g/min
Sulphur dioxide as SO ₂	1245-1447	34 mg/Nm ³	0.38 g/min
Sulphur dioxide as SO ₂ (Minimum)	1245-1447	1.3 mg/Nm ³	0.015 g/min
Sulphur dioxide as SO ₂ (Maximum)	1245-1447	65 mg/Nm ³	0.73 g/min
Carbon monoxide as CO	1245-1447	200 mg/Nm ³	2.3 g/min
Carbon monoxide as CO (Minimum)	1245-1447	12 mg/Nm ³	0.13 g/min
Carbon monoxide as CO (Maximum)	1245-1447	540 mg/Nm ³	6.1 g/min

Manual Sampling Results	Sampling Times	Concentration at NTP	Mass rate
Particulate matter	1240-1445	130 mg/m ³	1.4 g/min
Antimony	1240-1445	0.038 mg/m ³	0.00043 g/min
Arsenic	1240-1445	0.0036 mg/m ³	0.000040 g/min
Barium	1240-1445	0.032 mg/m ³	0.00036 g/min
Beryllium	1240-1445	< 0.0002 mg/m ³	< 0.000002 g/min
Cadmium	1240-1445	0.0025 mg/m ³	0.000028 g/min
Chromium	1240-1445	0.011 mg/m ³	0.00012 g/min
Cobalt	1240-1445	0.0011 mg/m ³	0.000012 g/min
Copper	1240-1445	0.050 mg/m ³	0.00056 g/min
Lead	1240-1445	0.42 mg/m ³	0.0047 g/min
Manganese	1240-1445	0.014 mg/m ³	0.00016 g/min
Mercury	1240-1445	0.0028 mg/m ³	0.000031 g/min
Nickel	1240-1445	0.034 mg/m ³	0.00038 g/min
Phosphorus	1240-1445	0.43 mg/m ³	0.0049 g/min
Selenium	1240-1445	0.0012 mg/m ³	0.000013 g/min
Silver	1240-1445	0.00060 mg/m ³	0.0000068 g/min
Thallium	1240-1445	< 0.0003 mg/m ³	< 0.000003 g/min
Tin	1240-1445	0.12 mg/m ³	0.0013 g/min
Vanadium	1240-1445	0.00078 mg/m ³	0.0000088 g/min
Zinc	1240-1445	4.3 mg/m ³	0.049 g/min